

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1209:215 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174  
Contact: \*Trish Linhart (630) 377-6674 Fax (630) 377-7245

**DESIGN:** Models BB-2 and BB-6 enclosures. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as an accessory for use with listee's separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation.

**XLF:** 7300-0028:194

\*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager